

CERTIFICATE

Issued to:
Applicant:
Eaglerise Electric & Electronic (China) Co., Ltd.
No. A3, Guicheng Sci-Tech Industrial Park,
Jianping Road, Nanhai District,
Foshan City, Guangdong Province, China

Licensee:
Eaglerise Electric & Electronic (China) Co., Ltd.
Beijiao Branch
No.4, East Huanzhen Road,
Beijiao Shunde,
528000 Foshan, Guangdong, China

Product : LED driver
Trade name(s) : EAGLERISE
Type(s)/model(s) : FLS-30-750 LA

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2178893

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 4 March 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-102989

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Rosa Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED driver
Trade name(s)	: EAGLERISE
Type(s)/model(s)	: FLS-30-750 LA
Rated voltage	: 220-240 V~
Rated frequency	: 50/60 Hz
Rated wattage	: 39,2 W MAX
Rated current	: 0,24 A MAX
Output current	: 500-750 mA
Output voltage range	: 24-42 Vdc
Max. output wattage	: 31,5 W MAX
Class of insulation	: Class II
Power factor	: $\geq 0,95$
Degree of protection	: IP20
Ambient temperature (ta)	: 50 °C
Max. case temperature (tc)	: 90 °C

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009

Test result

The test results are laid down in DEKRA test file 434162500.

Additional information

This certificate replaces certificate No. 35-102807 which we herewith declare invalid.

The list of components is laid down at test report 4341625.50.

Conclusion

The examination proved that all requirements were met.

Factory location

Eaglerise Electric & Electronic (China) Co., Ltd. Beijiao Branch
No.4, East Huanzhen Road,
Beijiao Shunde,
528000 Foshan, Guangdong, China

Trade name(s) : EAGLERISE stands for

