

# CE

**Declaration of Conformity** 

For the following equipment :

Product Name: Switching Power Supply

Model Designation: UHP-750-x (x=12,24,36,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

# RoHS Directive (2011/65/EU) 、(EU)2015/863

### Low Voltage Directive (2014/35/EU) :

EN62368-1:2014+A11

TUV certificate No : R50429926

Class B

# Electromagnetic Compatibility Directive (2014/30/EU) :

# EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55052.2015			
Harmonic current	EN61000-3-2:2014		
	LIN01000-3-2.2014		

Voltage flicker EN61000-3-3:2013

## EMS (Electro-Magnetic Susceptibility)

	1 1/		
EN55024:2010+A1:2015	EN61000-6-2:2005 EN55035:2017		
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltago dia interruption	EN61000 4 11:2004 > 05% dip 0.5 poriode 2	0% din 25 na	viada > 0.5% interruptions 250 pariada

Voltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods Note:

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies" (as available on <u>http://www.meanwell.com</u>)" and TDF (Technical Documentation File).

This Declaration is effective from serial number RB9xxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name) No.28, Wuguan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)	0		$\bigcirc$
Johnny Huang/Manager, Certification Center (Name / Position)	: <u> </u>	Alex Tsai/Director, Marketing Department : (Name / Position)	(Signature)
, ,	( )	(Name / Position)	(Signature)
Taiwan (Place)	Jul. 22nd, 2019 (Date)		